

Ref. No.: AL/EMD/MoEF/2019-20/F 02/008

Date: 20--05.2026

To

The Deputy Director General of Forest (C),
Ministry of Environment, Forest and Climate Change,
Integrated Regional Office, Kendriya Bhawan, 5th Floor, Sector-H,
Aliganj, Lucknow-226020 (UP), Email: rocz.lko-mef@nic.in

Sub.: Submission of the Six Monthly Compliance Report of stipulated conditions in the Environmental Clearance granted for Clinker Grinding Unit of Capacity 2.0 MTPA of M/s. J.K. Cement Works, at Village: Satha, Tehsil: Koil, District: Aligarh (UP) for the period: **Oct '2025 to Mar' 2026.**

Ref.: EC granted by SEIAA vide letter No.: 532/Parya/SEAC/4214/2018, dated 27th November, 2018.

Dear Sir,

This is context to the above subject & reference, we are submitting herewith the Six Monthly Compliance Report of stipulated conditions in Environmental Clearance granted by SEIAA, Lucknow (UP) for Clinker Grinding Unit of Capacity 2.0 Million TPA of M/s. J.K. Cement Works, at Village: Satha, Tehsil: Koil, District: Aligarh (UP) for the period: **Oct '2025 to Mar' 2026.** as per the above reference EC letter. In compliance with MoEF & CC O.M. dated 18.07.2022 we are also submitting a report on measures taken for spread awareness on Single Use Plastic Ban in plant premises.

As per MoEF & CC notification vide No.: S.O. 5845(E) dated 26.11.2018 regarding to submit the Environment Clearance Compliance Report in Soft Copy Only and in compliance to the same, we are hereby submitting the EC Compliance through e-mail for your kind reference and record please.

Thanking you,

Yours faithfully,

**For, J.K. Cement Works,**

(Vivek Sharma)
(Head - Grinding Unit)

Encl.: As above**Cc to:**

1. The Member Secretary, UP State Pollution Control Board, Building No. TC-12 V, Vibhuti Khand, Gomti Nagar, Lucknow-226 010, Email: ms@uppcb.com
2. The Regional Director, CPCB Regional Office, Zonal Office (North), PICUP Bhawan, Vibhuti Khand, Gomti Nagar, Lucknow-226 010, Email: skgupta110@yahoo.com
3. Regional Officer, UPPCB, J-1 Gyan Sarovar Colony, Ramghat Road, Aligarh, Email: roaligarh@uppcb.in

Corporate Office

- 📍 Prism Tower, 5th Floor, Ninaniya Estate, Gwal Pahari, Gurugram - 122102, Haryana
- ☎ +0124-6919000
- ✉ admin.prismt@jkcement.com
- 🌐 www.jkcement.com



**JK SUPER
CEMENT**
BUILD SAFE

Manufacturing Units at :

Nimbahera, Mangrol, Gotan (Rajasthan) | Muddapur (Karnataka) | Jharli (Haryana)
Katni, Panna (M.P.) | Aligarh, Hamirpur (U.P.) | Balasinor (Gujarat) | Fujairah

JK CEMENT
WallMaxX
White Cement Wall Putty



Your (**Half Yearly Compliance Report**) has been **Submitted** with following details

Proposal No	SIA/UP/IND/24160/2018
Compliance ID	1219818150
Compliance Number(For Tracking)	EC/M/COMPLIANCE/1219818150/2026
Reporting Year	2026
Reporting Period	01 Jun(01 Oct - 31 Mar)
Submission Date	25-05-2026
RO/SRO Name	Shri Satya Prakash Negi
RO/SRO Email	jhk119@ifs.nic.in
State	UTTAR PRADESH
RO/SRO Office Address	Integrated Regional Offices Lucknow

Note:- SMS and E-Mail has been sent to Shri Satya Prakash Negi, UTTAR PRADESH with Notification to Project Proponent.

Half Yearly Compliance Report**2026****01 Jun(01 Oct - 31 Mar)****Acknowledgement**

Proposal Name		Clinker Grinding Unit of Capacity 2.0 Million Ton per annum at Village Satha, Tehsil : Koil, District - Aligarh, U.P. by M/s. JK Cement Works, Aligarh	
Name of Entity / Corporate Office		M/s. JK Cement Works, Aligarh (A unit of JK Cement Limited)	
Village(s)		SATHA	
District		ALIGARH	
Proposal No.	SIA/UP/IND/24160/2018	Category	Industrial Projects - 1
Plot / Survey / Khasra No.		Sub-District	Koil
State	UTTAR PRADESH	Entity's PAN	*****0355R
MoEF File No.	532/Parya/SEAC/4214/2018	Entity name as per PAN	J K CEMENT LIMITED

Compliance Reporting Details

Reporting Year	2026
Remarks (if any)	Environment Clearance Compliance Report for the period Oct 2025 to March 2026.
Reporting Period	01 Jun(01 Oct - 31 Mar)

Details of Production and Project Area

Name of Entity / Corporate Office M/s. JK Cement Works, Aligarh (A unit of JK Cement Limited)

	Project Area as per EC Granted	Actual Project Area in Possession
Private	6.8318	6.8318
Revenue Land	0	0
Forest	0	0
Others	N/A	N/A
Total	6.8318	6.8318

Others Area

Sr. no	Other Name	Area Granted	Area Actual
--------	------------	--------------	-------------

Production Capacity

Sr. no	Product Name	units	Valid Upto	Capacity	Production last year	Capacity as per CTO
1	Cement	Million Tons per Annum (MTPA)	31/07/2026	2.0	1.27	2.0

Conditions

Specific Conditions

Sr.No.	Condition Type	Condition Details
1	ENERGY PRESERVATION MEASURES	Maximize utilization of fly ash, slag and sweetener in cement blend as per BIS standards.
PPs Submission: Being Complied Fly ash, slag is being used as per BIS norms in cement blend.		Date: 21/05/2026
2	WASTE MANAGEMENT	Kitchen waste shall be composted or converted to biogas for further use. (to be decided on case to case basis depending on type and size of plant).
PPs Submission: Being Complied Kitchen waste quantity is too less, hence biogas plant is not feasible.		Date: 21/05/2026
3	Noise Monitoring & Prevention	The ambient noise levels should conform to the standards prescribed under E(P)A Rules, 1986 viz. 75dB (A) during day time and 70dB (A) during night time.
PPs Submission: Being Complied Complying with.		Date: 21/05/2026
4	WASTE MANAGEMENT	The waste oil, grease and other hazardous shall be disposed of as per the Hazardous and Other waste (Management and Trans boundary Movement) Rules, 2016.
PPs Submission: Being Complied Hazardous waste is being sold to the CPCB/UPPCB authorized recyclers only.		Date: 21/05/2026
5	ENERGY PRESERVATION MEASURES	Provide solar power generation on roof tops of buildings, for solar light system for all common areas, street lights, parking around project area and maintain the same

		regularly.
PPs Submission: Being Complied Solar light has been installed in the common area.		Date: 21/05/2026
6	Statutory compliance	The project proponent shall obtain forest clearance under the provisions of Forest (Conservation) Act, 1986, in case of the diversion of forest land for non-forest purpose involved in the project.
PPs Submission: Complied There is no forest land involved in the project area. NOC Letter issued from DFO vide letter no. 2896 /14-10/ALIGARH dt. 27.02.2019, enclosed as Annexure-1. Hence, diversion of land is not applicable.		Date: 19/05/2026
7	Statutory compliance	The project proponent shall obtain clearance from the National Board for Wildlife, if applicable.
PPs Submission: Complied NOC from National Board for Wildlife is Not applicable.		Date: 19/05/2026
8	Statutory compliance	The project proponent shall prepare a Site- Specific Conservation Plan and Wildlife Management Plan and approved by the Chief Wildlife Warden. The recommendations of the approved Site-Specific Conservation Plan/ Wildlife Management Plan shall be implemented in consultation with the State Forest Department. The implementation report shall be furnished along with the six-monthly compliance report. (in case of the presence of schedule-I species in the study area).
PPs Submission: Complied Site- Specific Conservation Plan and Wildlife Management Plan is not applicable.		Date: 19/05/2026
9	Statutory compliance	The project proponent shall obtain Consent to Establish/ Operate under the provisions of Air (Prevention Control of Pollution) Act, 1981 and the Water (Prevention Control of Pollution) Act, 1974 from the concerned State pollution Control Board/Committee.

PPs Submission: Being Complied Consent to Establish has been obtained from UPPCB vide letter No. 26748/UPPCB/Aligarh(UPPCBRO) /CTE/Aligarh/ 2018, dated 20.08.2018. Consolidated Consent to Operate authorization has been obtained for under Section-25 of the Water (Prevention and Control of Pollution) Act, 1974 and under Section-21 of the Air (Prevention and Control of Pollution) Act, 1981 vide letter No.264000/UPPCB/Aligarh(UPPCBRO)/CTO/both/ALIGARH/2026 dt 21/03/26. granted for the period from 17/03/2026 to 31/07/2026. Copy of CCA is attached as Annexure-2.		Date: 19/05/2026
10	Statutory compliance	The project proponent shall obtain the necessary permission from the Central Ground Water Authority, in case of drawl of ground water from the competent authority concerned in case of drawl of surface water required for the project.
PPs Submission: Being Complied GW withdrawal NOC has been obtained from UPGWD with registration no.20210700720 and 202107000395 which is valid up to 08.08.2026. Copy of ground water permission is attached as annexure 3.		Date: 19/05/2026
11	Statutory compliance	The project proponent shall obtain authorization under the Hazardous and other Waste Management Rules, 2016 as amended from time to time.
PPs Submission: Being Complied HW authorization has been obtained from UPPCB vide letter no.264000/UPPCB/Aligarh(UPPCBRO)/CTO/both/ALIGARH/2026 dated: 21/03/2026. Copy of the same is attached as Annexure - 2.		Date: 19/05/2026
12	AIR QUALITY MONITORING AND PRESERVATION	The project proponent shall install 24x7 continuous emission monitoring system at process stacks to monitor stack emission with respect to standards prescribed in Environment (Protection) Rules, 1986 vide G.S.R. No. 612 (E) dated 25th August, 2014 (Cement) and subsequent amendment dated 9th May, 2016 (Cement) and connected to SPCB and CPCB online servers and calibrate these system from time to time according to equipment supplier specification through labs recognized under Environment (Protection) Act, 1986 or NABL accredited laboratories.
PPs Submission: Being Complied OCEMS for PM emission monitoring has been installed at Cement Mill stack and connected with server of SPCB and CPCB server for real time data		Date: 19/05/2026

transmission.		
13	AIR QUALITY MONITORING AND PRESERVATION	The project proponent shall monitor fugitive emissions in the plant premises at least once in every quarter through labs recognized under Environment (Protection) Act, 1986.
PPs Submission: Being Complied Fugitive emission is being monitored by NABL recognized Lab on regular basis. The result of the same are well within limit. Test report are attached as annexure 4.		Date: 19/05/2026
14	AIR QUALITY MONITORING AND PRESERVATION	The project proponent shall install system carryout to Ambient Air Quality monitoring for common /criterion parameters relevant to the main pollutants released (e.g. PM10 and PM2.5 in reference to PM emission, SO2 and NOX in reference to SO2 and NOX emissions) within and outside the plant area at least at four locations (one within and three outside the plant area at an angle of 120 degree each), covering up wind and downwind directions. (Case to case basis small plants :Manual; Large plants: Continuous).
PPs Submission: Being Complied Four nos. of Ambient air monitoring stations have been installed and monitoring is being done regularly. The NABL accredited laboratory report is attached as Annexure - 5.		Date: 19/05/2026
15	AIR QUALITY MONITORING AND PRESERVATION	The project proponent shall submit monthly summary report of continuous stack emission and air quality monitoring and results of manual stack monitoring and manual monitoring of air quality/fugitive emissions to Regional Office of MoEF and CC, Zonal office of CPCB and Regional Office of SPCB along with six-monthly monitoring report.
PPs Submission: Being Complied Stack emission monitored is being done by NABL certified third party lab. Result of the same are well within limits. Monitoring Report of stack monitoring is attached as annexure - 6.		Date: 19/05/2026
16	AIR QUALITY MONITORING AND PRESERVATION	Appropriate Air Pollution Control (APC) system shall be provided for all the dust

		generating points including fugitive dust from all vulnerable sources, so as to comply prescribed stack emission and fugitive emission standards.
PPs Submission: Being Complied Bag house at cement mill stack has been provided to maintain PM emission level of less than 30 mg/Nm ³ . Bag filters are provided at all transfer points.		Date: 19/05/2026
17	AIR QUALITY MONITORING AND PRESERVATION	The project proponent shall provide leakage detection and mechanised bag cleaning facilities for better maintenance of bags.
PPs Submission: Being Complied Mechanised bag cleaning facilities of Bag filters and Leakage detection system has been provided.		Date: 19/05/2026
18	AIR QUALITY MONITORING AND PRESERVATION	Pollution control system in the cement plant shall be provided as per the CREP Guidelines of CPCB.
PPs Submission: Being Complied Bag house at cement mill stack has been provided to maintain PM emission level of less than 30 mg/Nm ³ , Bag filters are provided at all transfer points, cemented roads has been constructed and regular vacuum sweeping machine is in practice. Covered storage for raw material and products has been provided and Covered hopper for unloading and Covered conveyor belts for transportation of material is provided. Photograph of bag house installed at cement mill is attached as Annexure - 7.		Date: 21/05/2026
19	AIR QUALITY MONITORING AND PRESERVATION	Sufficient number of mobile or stationery vacuum cleaners shall be provided to clean plant roads, shop floors, roofs, regularly.
PPs Submission: Being Complied 2 number of mechanical road sweeping machine has been deployed for road cleaning. Photograph of sweeping machines are enclosed as Annexure - 8.		Date: 21/05/2026
20	AIR QUALITY MONITORING AND PRESERVATION	Ensure covered transportation and conveying of raw material to prevent spillage and dust generation; Use closed bulkers for carrying fly ash.
PPs Submission: Being Complied Clinker is being transported through truck with covered tarpaulin. Fly ash is transported closed bulkers and stored in closed silo.		Date: 21/05/2026
21	AIR QUALITY MONITORING AND PRESERVATION	Provide wind shelter fence and chemicals spraying on the raw material stockpiles.

PPs Submission: Being Complied Covered storage facilities for the following raw materials have been provided i.e. Silo for Clinker, Shed for Gypsum and Silo for fly ash.		Date: 21/05/2026
22	AIR QUALITY MONITORING AND PRESERVATION	Have separate truck parking area and monitor vehicular emissions at regular interval.
PPs Submission: Being Complied Separate truck parking area has been provided and vehicle entry is allowed with valid PUC.		Date: 21/05/2026
23	AIR QUALITY MONITORING AND PRESERVATION	Efforts shall be made to reduce impact of the transport of the raw materials and end products on the surrounding environment including agricultural land by the use of covered conveyor belts/railways as a mode of transport.
PPs Submission: Being Complied Covered conveyor belts for transportation of the raw materials has been provided. Photograph of covered conveyor belt is enclosed as Annexure - 9.		Date: 21/05/2026
24	AIR QUALITY MONITORING AND PRESERVATION	Ventilation system shall be designed for adequate air changes as per ACGIH document for all tunnels, motor houses, Cement bagging plants.
PPs Submission: Being Complied Adequate ventilation system has been provided.		Date: 21/05/2026
25	WATER QUALITY MONITORING AND PRESERVATION	The project proponent shall install effluent monitoring system with respect to standards prescribed in Environment (Protection) Rules 1986 vide G.S.R. No. 612 (E) dated 25th August, 2014 (Cement) and sub sequent amendment dated 9th May, 2016 (Cement) and connected to SPCB and CPCB online servers and calibrate these systems from time to time according to equipment supplier specification through labs recognized under Environment (Protection) Act, 1986 or NABL accredited laboratories. (Case to case basis small plants: Manual; Large plants: Continuous).
PPs Submission: Being Complied Being a dry process based plant, there is no any effluent generation from		Date: 21/05/2026

Process.		
26	WATER QUALITY MONITORING AND PRESERVATION	The project proponent shall monitor regularly ground water quality at least twice a year (pre and post monsoon) at sufficient numbers of piezometers / sampling wells in the plant and adjacent areas through labs recognized under Environment (Protection) Act, 1986 and NABL accredited laboratories.
PPs Submission: Being Complied Ground water quality is being monitored regularly twice a year i.e. pre and post monsoon through NABL recognized lab. Report of the same is attached as Annexure -10		Date: 21/05/2026
27	WATER QUALITY MONITORING AND PRESERVATION	The project proponent shall submit monthly summary report of continuous effluent monitoring and results of manual effluent testing and manual monitoring of ground water quality to Regional Office of MoEF and CC, Zonal office of CPCB and Regional Office of SPCB along with six-monthly monitoring report.
PPs Submission: Being Complied Being a dry process based plant, there is no effluent generation from Process.		Date: 21/05/2026
28	WATER QUALITY MONITORING AND PRESERVATION	Adhere to Zero Liquid Discharge
PPs Submission: Being Complied Noted and being complied.		Date: 21/05/2026
29	WATER QUALITY MONITORING AND PRESERVATION	Sewage Treatment Plant shall be provided for treatment of domestic wastewater to meet the prescribed standards.
PPs Submission: Being Complied STP has been provided with a capacity of 15 KLD for treatment of domestic waste water to meet the prescribed standards. STP photograph enclosed as Annexure - 11.		Date: 21/05/2026
30	WATER QUALITY MONITORING AND PRESERVATION	Garland drains and collection pits shall be provided for each stock pile to arrest the run- off in the event of heavy rains and to check the water pollution due to surface runoff.
PPs Submission: Being Complied		Date:

All raw materials are stored under covered sheds and silos.		21/05/2026
31	WATER QUALITY MONITORING AND PRESERVATION	The project proponent shall practice rain water harvesting to maximum possible extent.
PPs Submission: Being Complied Three numbers of rain water harvesting structure has been provided. Photograph are enclosed as Annexure - 12.		Date: 21/05/2026
32	WATER QUALITY MONITORING AND PRESERVATION	Water meters shall be provided at the inlet to all unit processes in the cement plant.
PPs Submission: Complied Noted and complied with.		Date: 21/05/2026
33	WATER QUALITY MONITORING AND PRESERVATION	The project proponent shall make efforts to minimize water consumption in the cement plant complex by segregation of used water, practicing cascade use and by recycling treated water.
PPs Submission: Being Complied Continuous efforts have been taken to reduce water consumption. STP treated waste water is being reused in plantation and horticulture to reduce water consumption of plant.		Date: 21/05/2026
34	Noise Monitoring & Prevention	Noise level survey shall be carried as per the prescribed guidelines and report in this regard shall be submitted to Regional Officer of the Ministry as a part of six-monthly compliance report.
PPs Submission: Being Complied Noise monitoring is being carried out periodically and NABL certified third party monitoring report is attached as Annexure - 13		Date: 21/05/2026
35	ENERGY PRESERVATION MEASURES	Provide the project proponent for LED lights in their offices and residential areas.
PPs Submission: Being Complied LED lights in the offices has been provided.		Date: 21/05/2026
36	GREENBELT	Green belts shall be developed in an area equal to 33 percent of the plant area with a native tree species in accordance with CPCB guidelines. The greenbelt shall inter alia cover the entire periphery of the plant

PPs Submission: Being Complied Unit has planted 21465 sapling till March 2026.		Date: 21/05/2026
37	GREENBELT	The project proponent shall prepare GHG emissions inventory for the plant and shall submit the programme for reduction of the same including carbon sequestration including plantation.
PPs Submission: Being Complied Being complied. GHG emission inventory is being submitted along with company IR report. Report can be accessed at URL: extension://efaidnbmnnnibpcajpcglclefindmkaj/https://www.jkcement.com/wp-content/uploads/2025/06/JK-Cement-AR-2024-2025.pdf		Date: 21/05/2026
38	PUBLIC HEARING	Emergency preparedness plan based on the Hazard identification and Risk Assessment (HIRA) and Disaster Management Plan shall be implemented.
PPs Submission: Being Complied An emergency preparedness plan based on the Hazard identification and Risk Assessment (HIRA) and Disaster Management Plan has been prepared and implemented at site.		Date: 21/05/2026
39	PUBLIC HEARING	The PP shall provide Personal Protection Equipment (PPE) as per the norms of Factory Act.
PPs Submission: Being Complied Personal Protective Equipment (PPE) to Staff and Workmen are being provided.		Date: 21/05/2026
40	PUBLIC HEARING	Provision shall be made for the housing of construction labour within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water, medical health care, creche etc. The housing may be in the form of temporary structures to be removed after the completion of the project.
PPs Submission: Complied Not applicable as the project is in operation phase.		Date: 21/05/2026
41	PUBLIC HEARING	Occupational health surveillance of the workers shall be done on a regular basis and records maintained as per the Factories Act.

PPs Submission: Being Complied Regular Medical examinations are being done for the employee and workmen and records are being maintained.		Date: 21/05/2026
42	Corporate Environmental Responsibility	The project proponent shall comply with the provisions contained in this Ministry's OM vide F.No.22-65/2017-IA.III dated 1st May 2018, as applicable, regarding Corporate Environment Responsibility.
PPs Submission: Being Complied CER activities are going on and Rs.385.983 Lacs has been spent till Mar 2026.		Date: 21/05/2026
43	Corporate Environmental Responsibility	The company shall have a well laid down environmental policy duly approve by the Board of Directors. The environmental policy should prescribe for standard operating procedures to have proper checks and balances and to bring into focus any infringements/ deviation/ violation of the environmental/ forest / wildlife norms/ conditions. The company shall have defined system of reporting infringements/ deviation/ violation of the environmental/ forest/ wildlife norms / conditions and shareholders/ stake holders. The copy of the board resolution in this regard shall be submitted to the MoEF and CC as a part of six-monthly report.
PPs Submission: Being Complied Company has the Corporate Environment Policy duly approved by the Board of Directors. Copy has been submitted to the MoEF and CC. Copy enclosed as Annexure-14.		Date: 21/05/2026
44	Corporate Environmental Responsibility	A separate Environmental Cell both at the project and company head quarter level, with qualified personnel shall be set up under the control of senior Executive, who will directly report to the head of the organization.
PPs Submission: Being Complied The unit has a separate Env. Dept. under the control of the unit head. Organogram has been mentioned in the Environment Management System.		Date: 21/05/2026
45	Corporate Environmental Responsibility	Action plan for implementing EMP and environmental conditions along with

		responsibility matrix of the company shall be prepared and shall be duly approved by competent authority. The year wise funds earmarked for environmental protection measures shall be kept in separate account and not to be diverted for any other purpose. Year wise progress of implementation of action plan shall be reported to the Ministry /Regional Office along with the Six Monthly Compliance Report.
PPs Submission: Being Complied EMP expenditure Oct 2025 to Mar 2026 details are enclosed as Annexure - 15.		Date: 21/05/2026
46	Corporate Environmental Responsibility	Self-environmental audit shall be conducted annually. Every three years third party environmental audit shall be carried out.
PPs Submission: Being Complied Noted and being complied.		Date: 21/05/2026
47	Corporate Environmental Responsibility	All the recommendations made in the Charter on Corporate Responsibility for Environment Protection (CREP) for the cement plants shall be implemented.
PPs Submission: Being Complied Recommendations made in the Charter on Corporate Responsibility for Environment Protection (CREP) for the cement plants are being implemented Compliance status is give as below: 1. PM emission level of cement mill bag house is less then 30 mg/Nm3 2. All raw materials are stored in closed storage silos and shed. 3. All movement area is cemented. 4. Daily cleaning is done by vacuum sweeping machine. 5. All unloading hoppers are covered and provided with bag dust collectors 6. Bag dust collectors have been provided at all material transfer points. 7. All conveyor belts are covered.		Date: 21/05/2026
48	MISCELLANEOUS	Directions/ suggestions given during public hearing and Commitment made by the project proponent should be strictly complied.
PPs Submission: Being Complied Noted and being complied.		Date: 21/05/2026
49	MISCELLANEOUS	The project proponent shall make public the environmental clearance granted for their project along with the environmental conditions and

		safeguards at their cost by prominently advertising it at least in two local newspapers of the District or State, of which one shall be in the vernacular language within seven days and in addition this shall also be displayed in the project proponents web site permanently.
PPs Submission: Complied Advertised in newspapers on 04.12.2018 in Amar Ujala and Dainik Jagran. Copy has been submitted to the Ministry on 04.12.2018.		Date: 21/05/2026
50	MISCELLANEOUS	The copies of the environmental clearance shall be submitted by the project proponents to the Heads of local bodies, Panchayats and Municipal Bodies in addition to the relevant offices of the Government who in turn has to display the same for 30 days from the date of receipt.
PPs Submission: Complied Receipt of copy submitted to Heads of local bodies, Panchayats and Municipal Bodies in addition to the relevant offices of the Government has been submitted to the ministry on 04.12.2018		Date: 21/05/2026
51	MISCELLANEOUS	The project proponent shall upload the status of compliance of the stipulated environment clearance conditions, including results of monitored data on their website and update the same on half-yearly basis.
PPs Submission: Being Complied Six Monthly EC compliance report is being uploaded at company website at URL: https://www.jkcement.com/environmental-compliance/		Date: 21/05/2026
52	MISCELLANEOUS	The project proponent shall monitor the criteria pollutants level namely; PM10, SO2, NOX (ambient levels as well as stack emissions) or critical sectorial parameters, indicated for the projects and display the same at a convenient location for disclosure to the public and put on the website of the company.
PPs Submission: Being Complied Snapshot of digital display board is enclosed as Annexure - 16.		Date: 21/05/2026
53	MISCELLANEOUS	The project proponent shall submit six-monthly reports on

		the status of the compliance of the stipulated environmental conditions on the web site of the ministry of Environment, Forest and Climate Change at environment clearance portal.
PPs Submission: Being Complied Six-monthly reports on the status of the compliance of the stipulated environmental conditions submitted is being submitted on MoEF and CC - Parivesh portal vide Compliance Number(For Tracking): EC/M/COMPLIANCE/128258688 on dated 21/11/2025. Copy of Acknowledgement attached as Annexure - 17.		Date: 21/05/2026
54	MISCELLANEOUS	The project proponent shall submit the environmental statement for each financial year in Form-V to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently and put on the website of the company.
PPs Submission: Being Complied Environment Statement is being submitted regularly to Uttar Pradesh Pollution Control Board. For FY 24-25 Environment Statement is submitted vide letter No: AL/EMD/HOPB/ F 05 on dated 21.09.2025.		Date: 21/05/2026
55	MISCELLANEOUS	The project proponent shall inform the Regional Office as well as the Ministry, the date of financial closure and final approval of the project by the concerned authorities, commencing the land development work and start of production operation by the project.
PPs Submission: Complied The RO and HO, MoEFCC was informed via vide letter No. JK/Aligarh/EC/2018-19/F 03/004 dated 19.12.2018. Production operation started from 03.02.2020."		Date: 21/05/2026
56	MISCELLANEOUS	The project authorities must strictly adhere to the stipulations made by the State Pollution Control Board and the State Government.
PPs Submission: Complied Noted.		Date: 21/05/2026
57	MISCELLANEOUS	The project proponent shall abide by all the commitments and recommendations made in the EIA/EMP report, commitment made during

		Public Hearing and also that during their presentation to the Expert Appraisal Committee.
PPs Submission: Being Complied Noted and agreed.		Date: 21/05/2026
58	MISCELLANEOUS	No further expansion or modifications in the plant shall be carried out without prior approval of the Ministry of Environment Forests and Climate Change (MoEF and CC).
PPs Submission: Being Complied Noted and agreed.		Date: 21/05/2026
59	MISCELLANEOUS	Concealing factual data or submission of false/ fabricated data may result in revocation of this environmental clearance and attract action under the provisions of Environment (Protection) Act, 1986.
PPs Submission: Being Complied Noted and agreed.		Date: 21/05/2026
60	MISCELLANEOUS	The Ministry may revoke or suspend the clearance, if implementation of any of the above conditions is not satisfactory.
PPs Submission: Complied Noted and agreed.		Date: 21/05/2026
61	MISCELLANEOUS	The Ministry reserves the right to stipulate additional conditions if found necessary.
PPs Submission: Being Complied Noted and agreed.		Date: 21/05/2026
62	MISCELLANEOUS	The Company in a time bound manner shall implement these conditions.
PPs Submission: Being Complied Noted and being complied.		Date: 21/05/2026
63	MISCELLANEOUS	The Regional Office of this Ministry shall monitor compliance of the stipulated conditions. The project authorities should extend full

		cooperation to the officer(s) of the Regional Office by furnishing the requisite data / information / monitoring reports.
PPs Submission: Being Complied Noted and agreed.		Date: 21/05/2026
64	MISCELLANEOUS	The above conditions shall be enforced, inter-alia under the provisions of the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986, Hazardous and Other Wastes (Management and Trans boundary Movement) Rules, 2016 and the Public Liability Insurance Act, 1991 along with their amendments and Rules and any other orders passed by the Honble Supreme Court of India / High Courts and any other Court of Law relating to the subject matter.
PPs Submission: Being Complied Noted.		Date: 21/05/2026
65	MISCELLANEOUS	Any appeal against this EC shall lie with the National Green Tribunal, if preferred, within a period of 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.
PPs Submission: Being Complied Noted.		Date: 21/05/2026
Visit Remarks		
Last Site Visit Report Date:		N/A
Additional Remarks:		
Note: This acknowledgement is as per the details submitted by project proponent. In no way is this document to be considered as conclusion on any action on the compliance of the project. This is strictly for the project proponent's reference purpose.		

कार्यालय प्रभागीय निदेशक, सामाजिक वानिकी प्रभाग, अलीगढ़।

पत्रांक 2876/14-10, अलीगढ़ दिनांक फरवरी, 27, 2019

सेवा में,

यूनिट हेड
जे०के० सीमेंट वर्क्स,
सरिम्पुर रोड, ग्राम-साथा,
परगना-मोश्मल, तहसील-कोल,
जनपद-अलीगढ़-202127।

विषय:-

जे०के० सीमेंट वर्क्स, अलीगढ़ के खसरा सं० 126, 149, 150, 151, 151/1, 151/2, 151/3, 151/4, 152, 157, 158, 159 ए. 159/3 एवं 160/4, क्षेत्रफल 6.87 ग्राम- साथा, तहसील-कोल, जनपद-अलीगढ़ में वनभूमि होने/न होने के सम्बन्ध में।

संदर्भ:-

आपका पत्रांक JK/Aligarh/EC&FO/2018-19/FO&FO/001 dated 21.01.2019

उपरोक्त सन्दर्भित पत्र द्वारा याचित ग्राम-साथा, तहसील-कोल, जनपद-अलीगढ़ के अन्तर्गत खसरा सं० 126, 149, 150, 151, 151/1, 151/2, 151/3, 151/4, 152, 157, 158, 159 ए. 159/3 एवं 160/4, क्षेत्रफल 6.87 हे० के वनभूमि/गैर वनभूमि होने के सम्बन्ध में सूचना चाही गयी है। इस सम्बन्ध में जांचोपरांत क्षेत्रीय वन अधिकारी, अलीगढ़ रेंज ने अपने पत्र सं० 198/35-1 दि० 22.02.2019 द्वारा अवगत कराया गया है कि ग्राम साथा के अन्तर्गत उक्त खसरा संख्या जिसका कुल क्षेत्रफल 6.87 हे० है, वनभूमि नहीं है।

प्रति

(एस०डी० त्रिपाठी)

प्रभागीय निदेशक,

सामाजिक वानिकी प्रभाग, अलीगढ़।

पत्रांक

/14-1 समदिनांकित

प्रतिनिधि-

क्षेत्रीय वन अधिकारी, अलीगढ़ रेंज को उक्त पत्र सं० 198/35-1 दि० 22.02.2019 के क्रम में सूचना एवं आवश्यक कार्यवाही हेतु प्रेषित।

(एस०डी० त्रिपाठी)

प्रभागीय निदेशक,

सामाजिक वानिकी प्रभाग, अलीगढ़।



Uttar Pradesh Pollution Control Board

Building. No TC-12V Vibhuti Khand, Gomti Nagar, Lucknow-226010

Phone:0522-2720828,2720831, Fax:0522-2720764, Email: info@uppcb.in, Website: www.uppcb.com

Category : ORANGE

Application Id : 36153808

264000/UPPCB/Aligarh(UPPCBRO)/CTO/both/ALIGARH/2026

Date: 21/03/2026

To,

JK CEMENT LIMITED

ALIGARH - KASIMPUR ROAD, VILLAGE - SATHA, PARGANA - MORTHAL, TESHIL - KOIL, DISTRICT - ALIGARH, UP,ALIGARH,22127

Consolidated Consent to Operate and Authorisation hereinafter referred to as the CCA (Consolidated Consent & authorization) (Fresh) under Section-25 of the Water (Prevention & Control of Pollution) Act, 1974 and under Section-21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule-6(2) of the Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 notified under Environment (Protection) Act, 1986 as applicable (to be referred hereinafter as Water Act, Air Act and HW Rules respectively).

CCA is hereby granted to **JK CEMENT LIMITED** located at **ALIGARH - KASIMPUR ROAD, VILLAGE - SATHA, PARGANA - MORTHAL, TESHIL - KOIL, DISTRICT - ALIGARH, UP,ALIGARH,22127**. subject to the provisions of **the Water Act, Air Act and Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016** and the orders that may be made further and subject to following terms and conditions :-

1. This CCA JK CEMENT LIMITED **granted for the period from 17/03/2026 to 31/07/2026** and valid for manufacturing of following products.

S No	Product	Quantity	Unit
1	Portland Pozzolana Cement (PPC)/Ordinary Portland Cement (OPC)	2.0	Million Tonnes/Year

2. Conditions under Water(Prevention and Control of Pollution) Act -1974 as amended :-

(i) The daily quantity of effluent discharge (KLD) :-

Kind of Effluent	Quantity(KLD)	Treatment facility	Discharge point
Domestic	6.0	STP	Gardening

(ii) Trade Effluent Treatment and Disposal :-The applicant shall operate Effluent Treatment Plant consisting of primary/secondary and tertiary treatment as is required with reference to influent quantity and quality.

In case of stoppage of functioning of ETP, production has to be stopped immediately and this Board has to be intimated by fax/phone/email with a report in this regard to be dispatched immediately.

(iii) The treated effluent shall be recycled to the maximum extent and should be reused within the premises for gardening etc. Quality of the treated effluent shall meet to the following general and specific standards as prescribed under Environment (Protection) Rules, 1986 and applicable to the unit from time-to-time :-

Industrial Effluent Quality Standard

S.No.	Parameter	Standard
-------	-----------	----------

(iv) Sewage Treatment and Disposal :- The applicant shall provide comprehensive STP as is required with reference to influent quantity and quality. In case of stoppage of functioning of STP, production has to be stopped immediately and this Board has to be intimated by fax/phone/email with a report in this regard to be dispatched immediately.

(v) The treated sewage shall be reused in gardening as far as possible. The STP shall be maintained continuously so as to achieve the quality of the treated sewage to the following standards.

S No.	Parameters	Standards
-------	------------	-----------

3. Conditions under Air (Prevention and Control of Pollution) Act -1981 as amended :-

i) The applicant shall use following fuel and install a comprehensive control system consisting of control equipment as required with reference to generation of emissions and operate and maintain the same continuously so as to achieve the level of pollutants to the following standards.

Air Pollution Source Details

S No.	Air Pollution Source	Type of fuel	Stack no	Control Device	Height of Stack
1	125 KVA DG SET	DIESEL	06	Sulphur Dioxide	30 METER
2	1250 KVA DG SET	DIESEL	07	Sulphur Dioxide	30 METER
3	Cement Grinding Mill (Process Emission)	N.A.	01	Particulate Matter	43 Meter with Bag Filter
4	Packing Plant, Fly ash Silo and truck Tippler	NA	2,3,4,5	Particulate Matter	Bag Filter with 36.5 meter stack height

Emission Quality Standards

S No.	Stack no	Parameters	Standards
1	07	Particulate Matter	less than 0.2 g/kW-hr
2	07	Oxides of Nitrogen	less than 4.0 g/kW-hr
3	06	Particulate Matter	less than 0.2 g/kW-hr
4	06	Oxides of Nitrogen	less than 4.0 g/kW-hr
5	01	Particulate Matter	As per the EP Rules as amended
6	2,3,4,5	Particulate Matter	As per the EP Rules as amended

In case of stoppage of functioning of air pollution control equipment, production has to be stopped immediately and this Board has to be intimated by fax/phone/email with a report in this regard to be dispatched immediately

(ii) The unit will not use any type of restricted fuel.

iii) Noise from the D.G. Set and other source(s) should be controlled by providing an acoustic enclosure as is required for meeting the ambient noise standards for night and day time as prescribed for respective areas/zones (Industrial, Commercial, Residential, Silence) which are as follows :-

Day time : from 6.00 a.m. to 10.00 p.m., Night time: from 10.00 p.m. to 6.00 a.m.

Standards for Noise level in db(A) Leq	Industrial Area		Commercial Area		Residential Area		Silence Zone	
	Day Time	Night Time	Day Time	Night Time	Day Time	Night Time	Day Time	Night Time
	75	70	65	55	55	45	50	40

4. Conditions under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 :-

The Factory Manager of JK CEMENT LIMITED. is hereby granted an authorization to operate a facility for collection and storage of Hazardous wastes. The authorization is granted to operate a facility for generation, collection and storage of hazardous wastes within factory premises for following category of wastes:-

S.No.	Category of Hazardous Waste as per the Schedules I, II and III of these rules	Authorised mode of disposal or recycling or utilisation or co-processing, etc.	Quantity(ton/annum)
1	Spent Oil-23.2	Through TSDF	1.23 KL/Annum
2	Waste & Residue containing oil - 5.2	Through TSDF	2.0 KL/Annum
3	Contaminated cotton Waste Cloth- 33.2	Through TSDF	1.2 KL/Annum
4	Empty Barrels- 33.1	Through TSDF	300 No/Annum
5	used Oil-5.1	Through TSDF	6.0KL/Annum

The authorization shall be in force and shall be valid upto 31/07/2026. The authorization is subject to the conditions stated below and such conditions as may be specified in the rules for the time being in force under Environment (Protection) Act, 1986.

Terms and conditions of Hazardous Waste authorization :-

(i) The authorization shall comply with the provisions of the Environment (Protection) Act, 1986, and the rules made there under.

(ii) The authorization and its renewal shall be produced for inspection at the request of an officer authorized by the SPCB.

(iii) The person authorized shall not rent, lend, sell, transfer or otherwise transport the hazardous wastes without obtaining prior permission of the SPCB.

(iv) Any unauthorized changes in personnel, equipment as working conditions as mentioned in the application by the person authorized shall constitute a breach of his authorization.

(v) It is the duty of the authorized person to take prior permission of the SPCB to close down the facility.

(vi) An application for the renewal of an authorization shall be made as laid down under these rules.

(vii) The unit shall comply with any other conditions specified in the guidelines issued by the MoEF or CPCB/SPCB from time to time.

- (viii) The authorization is valid for temporary storage of Hazardous Waste within premises only.
- (ix) The authorized agency shall ensure that on-line data with regard to quantity and nature of hazardous chemicals being used in the plant as well as air emission and waste generated within premises is displayed on Display Board of size 6x4 feet outside the main factory gate within premises
- (x) It is duty of the authorized person to take prior permission of this Board to close and cleanup the facility for treatment, storage and disposal of hazardous waste.
- (xi) The applicant shall maintain record of hazardous waste in Form-3 and shall submit annual return in Form-4 on or before the 30th day of June following to the financial year to which that return relates.
- (xii) In no case any hazardous waste shall be disposed off on land, in any drain, or into any water stream. All spillage must also be safely collected and stored.
- (xiii) Before the hazardous waste is stored or dumped in the facility, applicant must conduct a detailed physical and chemical analysis of hazardous waste sample and report to the Board.
- (xiv) Dried hazardous sludge from the process in the plant shall be stored in double lined HDPE pit constructed with R.C.C. or such material which does not react with the waste contained in it.
- (xv) The storage area should be fenced properly and Sign/Notice Board indicating 'Danger' and 'Hazardous' shall be displayed at appropriate position both in Hindi and English.
- (xvi) The industry shall store non-ferrous metal waste, used oil/spent oil waste in sealed drums placed on impervious floor under covered shed. Hazardous waste if required shall be sold only to Registered Recyclers/Re-processors.
- (xvii) In case of any transportation of hazardous waste, the details in Form-10 of the Hazardous and Other Wastes Rules, 2016 shall be submitted to the Board.

5. Essential documents to be submitted by the Industry/Unit as Applicable:-

- (i) Annual return in Form-4 and Waste Disposal Manifest in Form-10 under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and Third Party Audit Report.
- (ii) Environment Statement in Form-V of Environment (Protection) Rules, 1986.
- (iii) Quarterly compliance report of the CCA, photograph of ETP/APCs/Waste Storage Area.

6. Competent Authority reserves the right to change/modify/add any time any condition of this CCA.

7. Unit has to comply with the following specific & general conditions. Non compliance of any provision of this CCA and provisions of the Water Act, Air Act and Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 will results in legal action under the aforesaid Acts and Rules.

8. In compliance to the G.O 1011/81-7-2021-09 (Writ)/2016 dated.13.10.2021 issued by Department of Environment, Forest and Climate Change, Uttar Pradesh. You are directed to develop Miyawaki Forest as per the SOP available at URL:-<http://www.upecp.in/TrainingSession.aspx> for ensuring timely compliance of this direction, you are hereby directed to submit a bank guarantee with minimum validity of one year of the amount equivalent to the sum of initial consent fees (Air and Water) or Rs. 50,000/- (Rs. Fifty Thousand Only) whichever is more, within 30 days from the date of issuance of this certificate. In case of non-compliance of this direction, your consent will be revoked by the Board.

9. If the unit uses the ground water and requires the permission from SGWA/CGWA for water abstraction then the industry will have to obtain No objection certificate for abstraction of ground water. It will be the responsibility of the industry to comply with the various conditions of the NOC obtained from the competent authority and submit to the Board, within 3 months time failing which CTO will be revoked.

General Conditions:-

1. The applicant shall get analysed the samples of effluent/emission/hazardous wastes at least once in a three month from the laboratory recognized by the MoEF and shall report to the UPPCB.
2. The applicant shall however, not without the prior consent of the Board bring into use any new or altered outlet for the discharge of effluent or gases emission or sewage waste from the unit.

3. Treated Industrial waste water and domestic waste water shall be disposed jointly at one disposal point. The applicant shall provide discharge measurement equipment at final disposal point.
4. The applicant shall strictly comply with conditions of this CCA and submit compliance report of stipulated conditions within 30 days of receipt of this CCA. If at any point of time, it is found that the industry is not complying with stipulated conditions or any further direction/instruction issued by the Board, legal action shall be initiated against the applicant.
5. The applicant shall maintain good house keeping. All valves/pipes/sewer/drains etc. must be leak-proof
6. The industry shall provide uninterrupted entry to the STP/ETP inlet and outlet points, Air Pollution Control equipment and stack for smooth sampling/monitoring of efficiency of pollution control systems.
7. The industry shall provide Inspection Book at the time of inspection to the Board's officials.
8. Whenever due to any accident or other unforeseen act or event, such emission occurs or is apprehended to occur in excess of standards laid down, such information shall be reported to the Board's offices and all other concerned offices. In case of failure of pollution control equipment, the production process connected to it shall be stopped with immediate effect.
9. The industry shall operate in a manner so that all emissions be emitted through designated chimney/stack only.
10. In case of any damage to the agriculture productivity, human habitation etc. by the operation of industry, it shall be imperative to stop production in the industry with immediate effect and such information shall be reported to Board's offices. The industry shall be liable to pay compensation also in such cases as decided by the Competent Authority.
11. The applicant shall apply before the 60 days of expiry of CCA or any change in production types/production capacity/manufacturing process/capacity enhancement etc. or any change in effluent discharge point or emission point
12. The Board reserves the right to revoke/add/modify any stipulated condition issued along with CCA, as may be necessary.

Specific Conditions:-

1. This Consent to operate is being issued/granted to M/s JK Cement Limited, Aligarh-Kasimpur Road, Vill. Satha, Pargana Lotha, Tehsil Koil Distt. Aligarh for Production of Portland Pozzolana Cement (PPC)/Ordinary Portland Cement (OPC)-2.0 Million TPA by using of Clinker-1.90 Million TPA, Fly Ash-0.80 Million TPA, Gypsum (Natural)- 0.30 Million TPA and Chemical Gypsum (Cat. 35.3, 26.1, 38.1)- 0.10 Million TPA.
2. This consent order is valid from dated 17.03.2026 to 31.07.2026 for the production of the above-mentioned product. Industry shall obtain prior approval before making any modification in product/process/fuel/plant machinery failing which consent would be deemed void.
3. No other air pollution source will be added/ installed by the unit without prior permission from State Pollution Control Board. If found the CTO will be revoked and necessary action will be initiated on the industry in accordance with Air (Prevention and Control of Pollution) Act 1981/Environment (P) Act, 1986.
4. This consent is valid only for discharge of domestic effluent Only through STP. No industrial discharged is allowed. If found the CTO will be revoked and necessary action will be taken on the industry in accordance with Water (Prevention and Control of Pollution) Act 1974/Environment (P) Act, 1986.
5. No water pollution source will be added/installed by the unit without prior permission from State Pollution Control Board
6. Industry should submit the calibration certificate of Electro Magnetic Flow meter in this office annually in each three month.
7. Industry should operate all Air Pollution Control Systems during Production.
8. Industry should transport the Clinker, Fly ash & Gypsum through covered Vehicles.
9. Industry should submit the calibration certificate of OCEMS in this office Annually.

10. Industry should submit the agreement form authorized TSDF for the disposal of Hazardous waste every year & and also form-10 manifest regularly.
11. Environmental statement will be submitted annually before the end of month of September every year.
12. Prior Consent to Establish (CTE) is mandatory as per the Hon'ble Supreme Court Order dt 08.12.2021 in IA no. 42482/2020 for any process change or addition in capacity in production or change in product.
13. Compliance report of CTO along with stack and ambient air Quality monitoring reports should be submitted by the industry quarterly to U.P Pollution Control Board. Industry shall register on UPPCB LIMS Portal for conducting Ambient Air Quality & Stack Monitoring form this office.
14. The unit shall submit stack monitoring report on every three months. Stack monitoring shall be conducted by the laboratories accredited by NABL or approved by MoEF CC, UPPCB or UPPCB Laboratory once in a year.
15. Industry should maintain the Rain Water Harvesting inside the industry premises.
16. Industry shall obtained the NOC for Fire from Fire Department & submit its copy in this office within three month.
17. The transportation of vehicles shall be in such a manner that emissions generated should not affect the nearby residence and agricultural field.
18. Extraction of groundwater through any mechanism like bore well etc. is not allowed without prior Registration/Permission from UP Ground Water Department (UPGWD).
19. Industry shall comply with various Waste Management Rules as notified by MoEF & CC i.e. Plastic Waste Management Rules, 2016, Solid Waste Management Rules, 2016, Hazardous Waste Management Rules, 2016, E-waste (Management) Rules, 2016, Construction and Demolition Waste Management Rules, 2016.
20. Industry shall submit annual returns as per the above-mentioned rules. Also, the Environmental Statement in the prescribed form as per Rule 14 of the Environment (Protection) Act, 1986.
21. For green belts at least 8 feet height plants should be planted which shall be properly protected as proper irrigation and maneuvering arrangements shall be made. Industry shall develop green belt in accordance with Government Order 07/55-02- 2018/09(writ)/2016 dated 26/02/2018 and UPPCB Office order issued vide letter no. H16405/220/2018/02 dated 16/02/2018 and letter no. H17259/ 183/55-2-2018/09(writ)/2016 dated 15.03.2018
22. The operation of the industry should be in the way that the process emission generated from the industry should not affect the surrounding environment and population.
23. Industry shall provide sufficient safety equipment to the workers for their safety.
24. If U.P.P.C.B or C.P.C.B issues a closure order against the industry, this consent shall remain suspended for the period till the closure order is revoked, after which the consent will be effective again for the remaining period.
25. This consent order will not affect the acceptance or order of any other department.
26. Knowingly making any false statement for obtaining consent or compliance with consent conditions shall result in the imposition of criminal penalties as provided under section 42(g) of the Water Act or section 38 (g) of the Air Act.
27. The applicant shall allow the staff of the Uttar Pradesh Pollution Control Board and/or their authorized representative, upon the representation of credentials:
 - a. To inspect raw material stock, manufacturing processes, reactors, premises etc. to perform the functions of the Board.
 - b. To enter upon the applicant's premises where an effluent source is located or in which any records are required to be kept under the terms and conditions of this consent.
 - c. To have access at reasonable times to any records required to be kept under the terms and condition of this consent.
28. This consent is transferable, in case of a change of ownership/management, and the addresses of the new

Owner/partner/directors/proprietor should immediately apply for the same.

29. The issuance of this consent does not convey any property rights in either real or personal property or any exclusive privileges, nor does it authorize any invasion of personal rights, nor any infringement of Central, State, or local laws or regulations.

30. This consent order is being issued with the intention that no pollution or land ownership dispute is pending and no such litigation is pending in any court, otherwise, the consent order will be deemed to be nullified.

31. In case of violation of the above-mentioned conditions, the consent order may be withdrawn.

32. This CTO is issued as per the provisions of the Air (Prevention and Control of Pollution) Act, 1981 (as amended) and the Water (Prevention and Control of Pollution) Act, 1974, and its amendment of 1978.

33. All effective safety measures shall be taken to avoid any contamination/deterioration in the surrounding environments/ecosystem.

34. Industry shall not dispose the solid waste in any case in the open area, public place, road, & river etc.

35. If the complaint is received against the industry regarding pollution, adverse impact on habitation and after verification, if the complaint is found true the CTO will be revoked without any prior notice.

Please note that Consent to Operate will be revoked, in case of, non compliance at any of the above mentioned conditions. Board reserves its right for amendment or cancellation of any of the conditions specified above. Industry is directed to submit the regular compliance report otherwise this Consent to Operate will be revoked.

Dr. VISHWANATH SHARMA
REGIONAL OFFICER

Copy to:

Chief Environment Officer, C-4, U.P. Pollution Control Board, TC-12V, Vibhuti Khand, Gomti Nagar, Lucknow.

Dr. VISHWANATH SHARMA
REGIONAL OFFICER



मिशन LIFE - पर्यावरण के लिए जीवन शैली (Lifestyle For Environment) जनसहभागिता का सन्देश



- स्वच्छता – देशसेवा में अपने परिवेश की स्वच्छता हेतु अपना सक्रिय योगदान सुनिश्चित करें
- संकल्प लें -एकल उपयोग प्लास्टिक उत्पाद जैसे कप, तश्तरी, चम्मच, स्ट्रॉ, ईयरबड्स आदि का उपयोग न हो एवं पर्यावरण अनुकूल विकल्पों जैसे कागज/पत्तों से बने दोने या कटलरी को प्राथमिकता दी जाय ।
- एकल उपयोग प्लास्टिक उत्पाद के प्रयोग को रोकने एवं प्लास्टिक बैग के बजाय कपड़े के थैले का उपयोग करने मात्र से 375 मिलियन टन ठोस (प्लास्टिक) कचरे का उत्सर्जन बचाया जा सकता है
- चक्रीय अर्थव्यवस्था (सर्कुलर इकोनॉमी) का समुचित कार्यान्वयन वर्ष 2030 तक लगभग 14 लाख करोड़ रुपये की अतिरिक्त बचत उत्पन्न कर सकता है । वेस्ट /अपशिष्ट फेंकने के पूर्व सोचें, ये किसी का संसाधन तो नहीं ...?
- अनुपयोगी इलेक्ट्रिक / इलेक्ट्रॉनिक उत्पाद को कचरे में फेंकने से रुकें । इसके उपयुक्त निस्तारण हेतु इसे प्राधिकृत ई – वेस्ट रीसाइकलर को दें । प्राधिकृत ई-रीसाइक्लिंग इकाई में अनुपयोगी इलेक्ट्रिक / इलेक्ट्रॉनिक उत्पाद को देने मात्र से 0.75 मिलियन टन तक ई-कचरे का पुनर्चक्रण किया जा सकता है एवं ई-कचरे के विषम पर्यावरणीय दुष्प्रभाव से बचा जा सकता है
- बाहर जाते समय - सोचें कि क्या आपको वास्तव में परिवहन की आवश्यकता है - वह भी क्या व्यक्तिगत रूप से ? छोटी दूरी के लिए पैदल चलना पसंद करें, अथवा सम्भव हो तो कार पूल के रूप में संसाधन को साझा करें अथवा सार्वजनिक परिवहन पर विचार करें
- घरेलू स्तर पर कम से कम ठोस अपशिष्ट का उत्सर्जन करें और इनका प्रथाक्रीकरण करें
- उपयोगी शेष खाद्य सामग्री आपके स्वयं प्रयास अथवा निकटस्थ सक्रिय स्वयं सेवी संस्थाओं की सहायता से समाज के वंचित वर्ग तक पहुंचाई जा सकती है । वहीं अनुपयोगी भोजन /खाद्य सामग्री को कंपोस्ट (वर्मी कम्पोस्ट) करने से 15 अरब टन भोजन को नष्ट होने से बचाया जा सकता है
- ध्यान रखें - उपयुक्त नल और शावर के उपयोग से पानी की खपत को 30 - 40% तक कम किया जा सकता है। एवं उपयोग में न होने पर नलों को बंद रखने मात्र से 9 ट्रिलियन लीटर पानी बचाया जा सकता है
- ट्रैफिक लाइट/रेलवे क्रॉसिंग पर कार/स्कूटर के इंजन बंद करने मात्र से 22.5 बिलियन kWh तक ऊर्जा की बचत हो सकती है
- परम्परागत बल्ब के स्थान पर CFL का उपयोग बिजली की खपत में प्रभावी कमी लाते हैं । उपयोग में न होने पर बिजली उपकरणों को बंद करें । स्टार रेटेड विद्युत उपकरणों के उपयोग को प्राथमिकता दें

हमारे द्वारा अपनी जीवन शैली की प्राथमिकताओं का उचित और पर्यावरण अनुकूल पुनर्निर्धारण समाज और पर्यावरण के प्रति हमारा दायित्व है ।



GROUND WATER DEPARTMENT

(Namami Gange & Rural Water Supply Department)

Ministry of Jal Shakti
Government of Uttar Pradesh



Form 8 (E)

[See rules 15(2)]

(RENEWAL OF AUTHORIZATION/ NO-OBJECTION CERTIFICATE FOR SINKING OF NEW WELL FOR INDUSTRIAL/ COMMERCIAL/ INFRASTRUCTURAL OR BULK USER OF GROUND WATER) VALID UP TO : 08/08/2026

Registration No.: 202107000395			
Name of the Owner	YADUPATI SINGHANIA		
Address of the Applicant	JK CEMENT LIMITED, PADAM TOWER, 19, DDA COMMUNITY CENTER, OKHLA PHASE - 1, NEW DELHI - 110020	Application Form Serial No.	ALGH0721RIN0034
Date of Submission	14/07/2021	Specimen Signature	
Company Name	JK CEMENT WORKS	Company Address	JK CEMENT WORKS ALIGARH VILLAGE SATHA BLOCK JAWAN
Location Particulars			
District	Aligarh	Block	JAWAN SIKANDER PUR
Plot No./Khasra No.	149	Municipality/Corporation	Yes
Ward No./Holding No.			N/A
Particular of the Existing Well and Pumping Device			
Date of Construction/Sinking of the Well	23/01/2019		
Type of Well	Tube Well/Boring	Depth of the Well (In meter)	100.00

Purpose of well	Industrial	Assembly Size(For Tube Well)	
Strainer Position (For Tube Well)			
Type of Pump Used	Submersible	H.P. of the Pump	15.00
Operational Device	Electric Motor	Rate of Withdrawal (m3/hr.)	46.00
Date of Energization (In Case of Electric Pump)		23/01/2019	
Maximum Allowable Rate of Withdrawal (m3/hr.):	46.00	Maximum Allowable Running Hours Per Day:	4.00
Maximum Allowable Annual Extraction of Ground Water:			64400
Reason for renewal of N.O.C. एन.ओ.सी. के नवीनीकरण का कारण	NOC DATE EXPIRED AND FILLING THE NEW APPLICATION		
Against Case			

This No-Objection certificate authorizes the owner applicant (user) to sink a well in the location specified at Sl. (3) for extraction of ground water at a rate not exceeding that as shown at Sl. (3j), for running hours I day as shown at Sl. (3k), and for maximum allowable annual extraction of ground water as shown at Sl. (3k) and is valid subject to the observance of the conditions stated overleaf.

Conditions

- (1) In case of any change of ownership of the proposed well, fresh authorization has to be obtained.
- (2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at SL (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this authorization.
- (3) For the purpose of measuring and recording the quantity of ground water extracted, every said user shall affix digital water flow meters(conforming to BIS/ IS standards) having telemetry system in the abstraction structure, which record rate and quantum of extraction, at outlet of pumping devices and it shall be presumed that the quantity recorded by the meter has been extracted by the said user, until the contrary is proved. The rate of extraction of ground water from the well as shown in item 3(k) shall not exceed to the recorded rate from water meters
- (4) The concerned Authority reserves the right to stop extraction of ground water from the well due to quality hazards or any other reasons, if the situation so demands.
- (5) In case of any change of ownership of the existing well, fresh registration has to be obtained.
- (6) No change of location, design, rate of withdrawal and pumping device in respect of the existing well as indicated at SL (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this registration.
- (7) n case, any of the particulars I information furnished by the applicant in his application for issuance of this registration is found to be incorrect during verification at any subsequent stage, this registration is liable for cancellation.
- (8) The Certificate of Authorization/ NOC shall be valid for a period of three years from the date of issue. The applicant shall have to apply for renewal through a fresh application, at least ninety days prior to expiry of its validity.
- (9) Construction of piezometers and installation of digital water level recorders with telemetry shall be mandatory for user. Depth and zone tapped of piezometer should be commensurate with that of the pumping well. The data, obtained from digital water level recorders shall be made available to this office on monthly basis.
- (10) Guidelines for Installation of Piezometers and their Monitoring
- Piezometer is a borewell /tube well used only for measuring the water level by lowering the tape/ sounder or automatic water level measuring equipment. It is also used to take water sample for water quality testing whenever needed. General guidelines for installation of piezometers are as follows for compliance of NOC:
 - The piezometer is to be installed/constructed at the minimum of 50 m distance from the pumping well through which ground water is being withdrawn. The diameter of the piezometer should be about 4" to 6".

- The depth of the piezometer should be same as is case of the pumping well from which ground water is being abstracted. If, more than one piezometer are installed the second piezometer should monitor the shallow ground water regime. It will facilitate shallow as well as deeper ground water aquifer monitoring.
- No. of piezometers to be constructed & Type of water level monitoring mechanism shall be as per below table:

S.No	Quantum of Ground water withdrawal (cum/day)	No.of piezometers required	Monitiring Mechanism	
			Manual	DWLR with Telemetry
1	< 10	0	0	0
2	11 - 50	1	1	0
3	50- 500	1	0	1
4	> 500	2	0	2

- The measuring frequency should be monthly and accuracy of measurement should be up to cm. the reported measurement should be given in meter up to two decimals.
- For measurement of water level sounder or automatic water level recorder (AWLR)/ Digital Automatic water level recorder (DWLR) with telemetry system should be used for accuracy.
- The measurement of water level in piezometer should be taken, only after the pumping from the surrounding tube wells has been stopped for about four to six hours.
- All the details regarding coordinates, reduced level (with respect to mean level), depth, zone taped and assembly lowered should be provided for bringing the piezometer into the Hydrograph Monitoring System for Ground Water Department, Uttar Pradesh, and for its validation.
- The ground water quality has to be monitored twice in a year during pre-monsoon (May/June) and post-monsoon (October/November) periods. Quality may be got analyzed from NABL approved lab. Besides, one sample (1 lt. capacity bottle) to the concerned Director, Ground Water Department, Uttar Pradesh, for chemical analysis.
- A Permanent display board should be installed at piezometer/Tube wells site for providing the location, piezometer/ tube well number, depth and zone tapped of piezometer/tube well for standard referencing and identification.
- Any other site-specific requirement regarding safety and access for measurement may be taken care off.
- (11) Any other condition(s) that may be imposed by the concerned Authority.
- (12) In case, any of the particulars I information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- **SPECIFIC CONDITIONS:**
- (A) **For Industrial User:** No Objection Certificate for ground water extraction by industries shall be granted subject to the following specific conditions:
 - i) No Objection Certificate shall be granted only in such cases where local government water supply agencies are not able to supply the desired quantity of water.
 - ii) All industries shall be required to adopt latest water efficient technologies so as to reduce dependence on ground water resources.
 - iii) All industries abstracting ground water in excess of 100 m³/d shall be required to undertake annual water audit through Confederation of Indian Industries (CII)/ Federation Indian Chamber of Commerce and Industry (FICCI)/ National Productivity Council (NPC) certified auditors and submit audit reports within three months of completion of the same to CGWA. All such industries shall be required to reduce their ground water use by at least 20% over the next three years through appropriate means.
 - iv) Construction of observation well(s) (piezometer)(s) within the premises and installation of appropriate water level monitoring mechanism as mentioned in General Condition no.10 shall be mandatory for industries drawing/ proposing to draw more than 10 m³/day of ground water and. Monitoring of water level shall be done by the project proponent. The piezometer (observation well) shall be constructed at a minimum distance of 15 m from the bore well/production well. Depth and aquifer zone tapped in the piezometer shall be the same as that of the pumping well/ wells. Monthly water level data shall be submitted online to the Ground Water Department, UP.
 - v) The proponent shall be required to adopt roof top rain water harvesting/ recharge in the project premises. Industries which are likely to pollute ground water (chemical, pharmaceutical, dyes, pigments, paints, textiles, tannery, pesticides/ insecticides, fertilizers, slaughter house, explosives etc.) shall store the harvested rain water in surface storage tanks for use in the industry.
 - vi) Injection of treated/ untreated waste water into aquifer system is strictly prohibited.
 - vii) Industries which are likely to cause ground water pollution e.g. Tanning, Slaughter Houses, Dye, Chemical/ Petrochemical, Coal washeries, other hazardous units etc. (as per CPCB list) need to undertake necessary well head protection measures to

ensure prevention of ground water pollution.

- (B) **Infrastructural User:** The No Objection Certificate for ground water abstraction will be granted subject to the following specific conditions:
- i) In case of infrastructure projects that require dewatering, proponent shall be required to carry out regular monitoring of dewatering discharge rate (using a digital water flow meter) and submit the data online to Ground Water Department, UP as applicable. Monitoring records and results should be retained by the proponent for two years, for inspection or reporting as required by District Ground Water Management Council.
- ii) Installation of Sewage Treatment Plants (STP) shall be mandatory for new projects, where ground water requirement is more than 20 m³ /day. The water from STP shall be utilized for toilet flushing, car washing, gardening etc.

This certificate is electronically generated and does not require digital signature

Annexure-5

J.K. Cement Works, Aligarh
Fugitive Emission Monitoring Report

Oct '2025 - March 2026

S.No.	Month/Year	SPM (mg/m ³)			
		NEAR UNLOADING	NEAR CEMENT	NEAR FLYASH	NEAR PACKING
1	Oct/25	1.60	1.62	1.62	1.59
2	Nov/25	1.60	1.60	1.62	1.58
3	Dec/25	1.57	1.62	1.61	1.60
4	Jan/26	1.56	1.63	1.61	1.62
5	Feb/26	1.59	1.62	1.58	1.61
6	Mar/26	1.58	1.61	1.55	1.60

Monitored By



Checked By





TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009, India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com




TEST REPORT


ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/015
Test Report No & Date	:	EETR/E/170326/015, DATE: 23.03.2026
ULR No.	:	TC166962600000779F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient air
Sampling Duration (min)	:	1332
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Near Plant boundary towards north direction
Ambient Temperature (°C)	:	28.9
Weather Condition	:	Clear
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026
Height of Monitoring Equipment Place	:	3.0 mtr
Equipment Used	:	Respirable Dust Sampler, Fine particulate Sampler, Gaseous Attachment

ANALYSIS RESULTS

S. No.	PARAMETERS	UNIT	RESULTS	NAAQ STANDARD (MAX)	TEST METHOD
1.	Particulate Matter (PM10)	[µg/m ³]	87	100	IS :5182 (P-23) : 2006
2.	Sulphur Dioxide (as SO ₂)	[µg/m ³]	18	80	IS :5182 (P-2)/Sec:1 : 2023
3.	Nitrogen Dioxide (as NO ₂)	[µg/m ³]	41	80	IS :5182 (P-6): 2006
4.	Particulate Matter (PM2.5)	[µg/m ³]	46	60	IS :5182 (P-24) : 2019


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

1.4

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-18696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT


ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/016
Test Report No & Date	:	EETR/E/170326/016, DATE: 23.03.2026
ULR No.	:	TC166962600000780F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient air
Sampling Duration (min)	:	1296
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Near Plant boundary towards west direction
Ambient Temperature (°C)	:	29.1
Weather Condition	:	Clear
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026
Height of Monitoring Equipment Place	:	3.0 mtr
Equipment Used	:	Respirable Dust Sampler, Fine particulate Sampler, Gaseous Attachment

ANALYSIS RESULTS

S. No.	PARAMETERS	UNIT	RESULTS	NAAQ STANDARD (MAX)	TEST METHOD
1.	Particulate Matter (PM10)	[µg/m ³]	90	100	IS :5182 (P-23) : 2006
2.	Sulphur Dioxide (as SO ₂)	[µg/m ³]	21	80	IS :5182 (P-2)/Sec:1 : 2023
3.	Nitrogen Dioxide (as NO ₂)	[µg/m ³]	40	80	IS :5182 (P-6): 2006
4.	Particulate Matter (PM2.5)	[µg/m ³]	52	60	IS :5182 (P-24) : 2019


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

2



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenlab.com, Website : www.evergreenlab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/017
Test Report No & Date	:	EETR/E/170326/017, DATE: 23.03.2026
ULR No.	:	TC166962600000781F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient air
Sampling Duration (min)	:	1248
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Near Plant boundary towards east direction
Ambient Temperature (°C)	:	28.9
Weather Condition	:	Clear
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026
Height of Monitoring Equipment Place	:	3.0 mtr
Equipment Used	:	Respirable Dust Sampler, Fine particulate Sampler, Gaseous Attachment

ANALYSIS RESULTS

S. No.	PARAMETERS	UNIT	RESULTS	NAAQ STANDARD (MAX)	TEST METHOD
1.	Particulate Matter (PM10)	[µg/m ³]	89	100	IS :5182 (P-23) : 2006
2.	Sulphur Dioxide (as SO ₂)	[µg/m ³]	22	80	IS :5182 (P-2)/Sec:1 : 2023
3.	Nitrogen Dioxide (as NO ₂)	[µg/m ³]	38	80	IS :5182 (P-6): 2006
4.	Particulate Matter (PM2.5)	[µg/m ³]	49	60	IS :5182 (P-24) : 2019


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

113



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT


ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/018
Test Report No & Date	:	EETR/E/170326/018, DATE: 23.03.2026
ULR No.	:	TC166962600000782F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient air
Sampling Duration (min)	:	1284
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Near Plant boundary towards south direction
Ambient Temperature (°C)	:	29.2
Weather Condition	:	Clear
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026
Height of Monitoring Equipment Place	:	3.0 mtr
Equipment Used	:	Respirable Dust Sampler, Fine particulate Sampler, Gaseous Attachment

ANALYSIS RESULTS

S. No.	PARAMETERS	UNIT	RESULTS	NAAQ STANDARD (MAX)	TEST METHOD
1.	Particulate Matter (PM10)	[µg/m3]	85	100	IS :5182 (P-23) : 2006
2.	Sulphur Dioxide (as SO2)	[µg/m3]	16	80	IS :5182 (P-2)/Sec:1 : 2023
3.	Nitrogen Dioxide (as NO2)	[µg/m3]	34	80	IS :5182 (P-6): 2006
4.	Particulate Matter (PM2.5)	[µg/m3]	55	60	IS :5182 (P-24) : 2019


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report
Page1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870. Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/027
Test Report No. & Date	:	EETR/E/170326/027, DATE: 23.03.2026
ULR No.	:	TC166962600000791F
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Stack Emission (Cement Mill)
Emission source Monitored	:	Cement Mill (260 Ton/hr)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	Metal
Type of Fuel	:	Electricity
Stack Height in Meter from Ground Level (mtr)	:	43
Diameter of Stack (Mtr.)	:	2.36
Sampling Duration (min)	:	87
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM, NOx, CO, SOx
Stack temperature (°C)	:	116
Ambient Temperature (°C)	:	28.9
Stack Velocity (M/Sec)	:	8.30
Quantity of Emission (Nm ³ /hr)	:	98077.61
Flow Rate Of PM	:	13.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER CPCB	TEST METHOD
1.	Particulate Matter (PM)	mg/Nm ³	15.2	30	IS : 11255 (part-1): 1985
2.	Oxides of Nitrogen (as NOx)	mg/Nm ³	6.3	Not Specified	IS : 11255 (part-7) : 2005
3.	Carbon Monoxide (as CO)	% by vol.	0.4	1.0	IS:13270 : 1992
4.	Sulphur Dioxide (as SOx)	mg/Nm ³	3.4	Not Specified	IS : 11255 (part-2) : 1985

Reviewed by
PARDEEP



End of the Report
Page 1 of 1

Evergreen Enviro Testing LLP.

Authorised By

Authorised Signatory
Chandan Kumar Singh

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenecolab.com, Website : www.evergreenecolab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/028
Test Report No. & Date	:	EETR/E/170326/028, DATE: 23.03.2026
ULR No.	:	TC166962600000792F
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Stack Emission
Emission source Monitored	:	Packing Plant bag filter-1 (31000m ³ /hr)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Stack Height in Meter from Ground Level (mtr)	:	36.5
Diameter of Stack (Mtr.)	:	1.1
Sampling Duration (min)	:	56
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM
Stack temperature (°C)	:	109
Ambient Temperature (°C)	:	28.9
Stack Velocity (M/Sec)	:	7.97
Quantity of Emission (Nm ³ /hr)	:	20324.439
Control measure (if any)	:	BAG Filter
Flow Rate Of PM	:	18.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER CPCB	TEST METHOD
1.	Particulate Matter (PM)	mg/Nm ³	12.7	Not Specified	IS :11255 (part-1): 1985

Pardeep
Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report

Page 1 of 1

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenecolab.com, Website : www.evergreenecolab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/029
Test Report No. & Date	:	EETR/E/170326/029, DATE: 23.03.2026
ULR No.	:	TC166962600000793F
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Stack Emission
Emission source Monitored	:	Packing Plant bag filter-2 (31000m ³ /hr)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Stack Height in Meter from Ground Level (mtr)	:	36.5
Diameter of Stack (Mtr.)	:	1.1
Sampling Duration (min)	:	59
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM
Stack temperature (°C)	:	108
Ambient Temperature (°C)	:	29.4
Stack Velocity (M/Sec)	:	7.76
Quantity of Emission (Nm ³ /hr)	:	20207.565
Control measure (if any)	:	Bag Filter
Flow Rate Of PM	:	17.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER CPCB	TEST METHOD
1.	Particulate Matter (PM)	mg/Nm ³	11.9	Not Specified	IS : 11255 (part-1): 1985

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenclab.com, Website : www.evergreenclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/030
Test Report No. & Date	:	EETR/E/170326/030, DATE: 23.03.2026
ULR No.	:	TC166962600000794F
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Stack Emission
Emission source Monitored	:	Packing Plant bag filter-3 (31000m ³ /hr)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Stack Height in Meter from Ground Level (mtr)	:	36.5
Diameter of Stack (Mtr.)	:	1.1
Sampling Duration (min)	:	85
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM
Stack temperature (°C)	:	111
Ambient Temperature (°C)	:	29.7
Stack Velocity (M/Sec)	:	7.84
Quantity of Emission (Nm ³ /hr)	:	20459.28
Control measure (if any)	:	BAG Filter
Flow Rate Of PM	:	12.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER CPCB	TEST METHOD
1.	Particulate Matter (PM)	mg/Nm ³	12.2	Not Specified	IS :11255 (part-1): 1985

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/031
Test Report No. & Date	:	EETR/E/170326/031, DATE: 23.03.2026
ULR No.	:	TC166962600000795F
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Stack Emission
Emission source Monitored	:	Packing Plant bag filter-4 (31000m ³ /hr)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Stack Height in Meter from Ground Level (mtr)	:	36.5
Diameter of Stack (Mtr.)	:	1.1
Sampling Duration (min)	:	80
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM
Stack temperature (°C)	:	115
Ambient Temperature (°C)	:	29.4
Stack Velocity (M/Sec)	:	7.99
Quantity of Emission (Nm ³ /hr)	:	20543.48
Control measure (if any)	:	BAG Filter
Flow Rate Of PM	:	12.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER CPCB	TEST METHOD
1.	Particulate Matter (PM)	mg/Nm ³	11.3	Not Specified	IS :11255 (part-1): 1985


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/032
Test Report No. & Date	:	EETR/E/170326/032, DATE: 23.03.2026
ULR No.	:	TC166962600000796P
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Gen Set Stack Emission
Emission source Monitored	:	Gen Set Stack No.-1 (1250 KVA)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Type Of Fuels	:	HSD
Stack Height in Meter from Ground Level (mtr)	:	30
Diameter of Stack (Mtr.)	:	0.2
Sampling Duration (min)	:	51
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM, NOx, CO, SOx
Stack temperature (°C)	:	118
Ambient Temperature (°C)	:	29.9
Stack Velocity (M/Sec)	:	10.88
Quantity of Emission (Nm ³ /hr)	:	919.48
Flow Rate Of PM	:	20.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS CAQM	TEST METHOD
1.	Particulate Matter (PM) at 15% O ₂	mg/Nm ³	37	50	IS :11255 (part-1): 1985
2.	Oxides of Nitrogen(as NOx) at 15% O ₂	mg/Nm ³	181.5	650	IS :11255 (part-7) : 2005
3.	Carbon Monoxide (as CO) at 15% O ₂	%	BDL	Not Specified	IS:13270 : 1992
4.	Sulphur Dioxide (as SOx)	mg/Nm ³	30	Not Specified	IS :11255 (part-2) : 1985

BDL: Below Detection Limits

Reviewed by
PARDEEP

End of the Report
Page 1 of 1

Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.

EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

Test Report No. & Date	:	EETR/E/170326/032, DATE: 23.03.2026
------------------------	---	-------------------------------------

ANALYSIS RESULT

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS	TEST METHOD
1.	Non methane Hydrocarbon	mg/Nm ³	14	100	EET/STP/CHEM/32

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note :
1. The result listed refer only to be Tested samples and applicable parameters.
 2. Perishable samples will be destroyed after 15 days of sampling.
 3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
 4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/033
Test Report No. & Date	:	EETR/E/170326/033, DATE: 23.03.2026
ULR No.	:	TC166962600000797P
Sampling Method	:	As per CPCB Norm's
Sample Description	:	Stack Emission
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Reference	:	EP Act std.
Sampled By	:	EET Representative
Name of Plant & Section	:	Gen Set Stack Emission
Emission source Monitored	:	Gen Set Stack No.-2 (125 KVA)
Normal Operating Schedule	:	As & when required
Type of Chimney (Acc /Metal)	:	M.S
Type Of Fuels	:	HSD
Stack Height in Meter from Ground Level (mtr)	:	30
Diameter of Stack (Mtr.)	:	0.25
Sampling Duration (min)	:	48
Purpose of Monitoring	:	Assessment of Pollution Load
Parameters Monitoring	:	PM, NOx, CO, SOx
Stack temperature (°C)	:	107
Ambient Temperature (°C)	:	28.5
Stack Velocity (M/Sec)	:	10.54
Quantity of Emission (Nm3/hr)	:	1424.4677
Flow Rate Of PM	:	21.0
Flow Rate Of Gases	:	2.0

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS AS PER GSR 281(E)	TEST METHOD
1.	Particulate Matter (PM)	gm/kw-hr	0.17	≤0.2	IS :11255 (part-1): 1985
2.	Oxides of Nitrogen(as NOx)	gm/kw-hr	1.08	≤4.0	IS :11255 (part-7) : 2005
3.	Carbon Monoxide (as CO)	gm/kw-hr	BDL	≤3.5	IS:13270 : 1992
4.	Sulphur Dioxide (as SOx)	gm/kw-hr	0.38	Not Specified	IS :11255 (part-2) : 1985

BDL: Below Detection Limits

Pardeep

Reviewed by
PARDEEP



End of the Report
Page 1 of 1

Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.

EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com


Test Report No. & Date	:	EETR/E/170326/033, DATE: 23.03.2026
------------------------	---	-------------------------------------

ANALYSIS RESULT

S.NO.	PARAMETERS	UNITS	RESULTS	EMISSION LIMITS	TEST METHOD
1.	Non methane Hydrocarbon	gm/kw-hr	0.40	≤4.0	EET/STP/CHEM/32


Reviewed by
PARDEEP

Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh



End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

Stack Emmission 2025-26 (In PM mg/Nm3)						
Location	Month					
	Oct/25	Nov/25	Dec/25	Jan/26	Feb/26	Mar/26
CEMENT MILL	13.6	13.7	13.7	11.7	10.2	15.2



Baq Filter Photograph



Road Sweeping Machine



Road Sweeping Machine

Raw Material Handling Covered Procedure





TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenecolab.com, Website : www.evergreenecolab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/042
Test Report No. & Date	:	EETR/E/170326/042, DATE: 23.03.2026
ULR No.	:	TC166962600000802F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ground Water
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Site	:	Borewell-1
Sample Quantity	:	2 + 1 Ltr.
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	Ok
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Sr.No	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
Physical parameter						
1.	pH	-	8.11	6.5-8.5	No relaxation	IS 3025 (Part-11):2022
2.	Colour	CU	<1	5	15	IS 3025 (Part-4):2021
3.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (part-5): 2018
4.	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2017
5.	Turbidity	NTU	<5	1	5	IS 3025 (Part-10):2023
6.	Total Dissolved Solids(TDS)	mg/l	412	500	2000	IS 3025 (Part-16):2023

BDL: Below Detection limit,

DL: Detection limit

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By
Authorised Signatory
Chandan Kumar Singh

Page 1 of 4

1-7

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TC-16696

Test Report No & Date

EETR/E/170326/042, DATE: 23.03.2026

ANALYSIS RESULT

Sr.No.	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
General Parameter						
1.	Total Hardness (as CaCO3)	mg/l	198	200	600	IS 3025 (Part-21):2009
2.	Alkalinity as CaCO3 (Total& Phenolphthalein)	mg/l	178	200	600	IS 3025 (Part-23):2023
3.	Cyanide(as CN)	mg/l	BDL (DL-0.02)	0.05	No relaxation	IS 3025 (Part- 27/sec 1): 2021
4.	Chloride (as Cl)	mg/l	56.2	250	1000	IS 3025 (Part-32):2025
5.	Sulphate (as SO4)	mg/l	31.4	200	400	IS 3025 (Part- 24/sec 1): 2022
6.	Sulphide (as H2S)	mg/l	BDL (DL-0.05)	0.05	No relaxation	IS 3025 (Part-29):2022
7.	Chloramine (as Cl2)	mg/l	BDL(DL-0.1)	-	-	IS 3025 (Part-26):2021
8.	Phenolic Compounds (as C6H5OH)	mg/l	BDL (DL-0.02)	0.001	0.002	IS 3025 (Part- 43/sec 1) : 2022
9.	Fluoride (as F)	mg/l	BDL(DL-0.1)	1.0	1.5	IS 3025 (Part- 60):sec- 1 : 2023
10.	Nitrite (as NO2)	mg/l	BDL (DL-0.02)	No relaxation	No relaxation	IS 3025 (Part-34/sec 1): 2023
11.	Anionic Surfactant (as MBAS)	mg/l	BDL (DL-0.1)	0.2	1.0	IS 3025 (Part-68):2019
12.	Hexavalent Chromium (as Cr+6)	mg/l	BDL (DL-0.05)	0.05	No relaxation	IS 3025 (Part-52):2003
13.	Nitrate (as NO3)	mg/l	BDL(DL-0.1)	45	-	IS 3025 (Part- 34)/Sec:1: 2023
14.	Calcium (as Ca)	mg/l	49.6	75	200	IS 3025 (Part-40):2024
15.	Magnesium (as Mg)	mg/l	18.0	30	100	IS 3025 (Part-46):2023
16.	Iron (as Fe)	mg/l	BDL(DL-0.05)	1.0	No relaxation	IS 3025 (Part-53):2024
17.	Manganese (as Mn)	mg/l	BDL(DL-0.05)	0.1	0.3	IS 3025 (Part-59):2023
18.	Zinc(as Zn)	mg/l	BDL(DL-0.5)	5.0	15	IS 3025 (Part-49):2024
19.	Mercury (as Hg)	mg/l	BDL(DL-0.05)	0.001	No relaxation	IS 3025 (Part-48):2025

BDL: Below Detection limit,
DL: Detection limit

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By
Authorised Signatory
Chandan Kumar Singh

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com




Test Report No & Date

EETR/E/170326/042, DATE: 23.03.2026

ANALYSIS RESULT

Sr.No.	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
20.	Selenium(as Se)	mg/l	BDL(DL-0.05)	0.01	No relaxation	IS 3025 (Part-56):2003
21.	Aluminium(as Al)	mg/l	BDL(DL-0.05)	0.03	0.2	IS 3025 (Part-55):2003
22.	Lead (as Pb)	mg/l	BDL(DL-0.05)	0.01	No relaxation	IS 3025 (Part-47):2024
23.	Total Chromium (as Cr)	mg/l	BDL(DL-0.05)	0.05	No relaxation	IS 3025 (Part- 52):2003
24.	Boron (as B)	mg/l	BDL(DL-0.3)	0.5	1.0	IS 3025 (Part-57): 2021
25.	Cadmium(as Cd)	mg/l	BDL(DL-0.05)	0.003	No relaxation	IS 3025 (Part-41): 2023

BDL: Below Detection limit,
DL: Detection limit


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenlab.com, Website : www.evergreenlab.com



Test Report No & Date

EETR/E/170326/042, DATE: 23.03.2026

ANALYSIS RESULT

S. No.	Parameters	Unit	Results	Specification/ Limits As Per IS 10500:2012		Test Method
				Requirement Limit	Permissible Limit	
Biological in water						
1.	Escherichia Coli	MPN /100ml	<2	<2 MPN /100ml	No Relaxation	IS:1622:1981
2.	Total Coliform	MPN /100ml	<2	<2 MPN /100ml	No Relaxation	IS:1622:1981

Neelam
Reviewed by
NEELAM SHARMA

Evergreen Enviro Testing LLP
Surbhi
Authorized Signatory
Surbhi Sharma

End of the Report

Page 4 of 4



- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

3



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/043
Test Report No. & Date	:	EETR/E/170326/043, DATE: 23.03.2026
ULR No.	:	TC166962600000803F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ground Water
Sample Collected by	:	EET Representative (Mr.Yatesh)
Sampling Site	:	Borewell-2
Sample Quantity	:	5 + 1 Ltr.
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	Ok
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULT

Sr.No	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
Physical parameter						
1.	pH	-	8.05	6.5-8.5	No relaxation	IS 3025 (Part-11):2022
2.	Colour	CU	<1	5	15	IS 3025 (Part-4):2021
3.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (part-5): 2018
4.	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2017
5.	Turbidity	NTU	<5	1	5	IS 3025 (Part-10):2023
6.	Total Dissolved Solids(TDS)	mg/l	385	500	2000	IS 3025 (Part-16):2023

BDL: Below Detection limit,
DL: Detection limit


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



Test Report No & Date

EETR/E/170326/043, DATE: 23.03.2026

ANALYSIS RESULT

Sr.No.	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
General Parameter						
1.	Total Hardness (as CaCO3)	mg/l	183	200	600	IS 3025 (Part-21): 2009
2.	Alkalinity as CaCO3 (Total& Phenolphthalein)	mg/l	168	200	600	IS 3025 (Part-23):2023
3.	Cyanide (as CN)	mg/l	BDL (DL-0.02)	0.05	No relaxation	IS 3025 (Part- 27/sec 1): 2021
4.	Chloride (as Cl)	mg/l	51	250	1000	IS 3025 (Part-32):2025
5.	Sulphate (as SO4)	mg/l	28.3	200	400	IS 3025 (Part- 24/sec 1): 2022
6.	Sulphide (as H2S)	mg/l	BDL (DL-0.05)	0.05	No relaxation	IS 3025 (Part-29):2022
7.	Chloramine (as Cl2)	mg/l	BDL(DL-0.1)	-	-	IS 3025 (Part-26):2021
8.	Phenolic Compounds (as C6H5OH)	mg/l	BDL (DL-0.02)	0.001	0.002	IS 3025 (Part- 43/sec 1) : 2022
9.	Fluoride (as F)	mg/l	BDL(DL-0.1)	1.0	1.5	IS 3025 (Part- 60):sec- 1 : 2023
10.	Nitrite (as NO2)	mg/l	BDL (DL-0.02)	No relaxation	No relaxation	IS 3025 (Part-34/sec 1): 2023
11.	Anionic Surfactant (as MBAS)	mg/l	BDL (DL-0.1)	0.2	1.0	IS 3025 (Part-68):2019
12.	Hexavalent Chromium (as Cr+6)	mg/l	BDL (DL-0.05)	0.05	No relaxation	IS 3025 (Part-52): 2003
13.	Nitrate (as NO3)	mg/l	BDL(DL-0.1)	45	-	IS 3025 (Part-34)/Sec:1: 2023
14.	Calcium (as Ca)	mg/l	42	75	200	IS 3025 (Part-40): 2024
15.	Magnesium (as Mg)	mg/l	19.2	30	100	IS 3025 (Part-46): 2023
16.	Iron (as Fe)	mg/l	BDL(DL-0.05)	1.0	No relaxation	IS 3025 (Part-53): 2024
17.	Manganese (as Mn)	mg/l	BDL(DL-0.05)	0.1	0.3	IS 3025 (Part-59): 2023
18.	Zinc (as Zn)	mg/l	BDL(DL-0.5)	5.0	15	IS 3025 (Part-49): 2024
19.	Mercury (as Hg)	mg/l	BDL(DL-0.05)	0.001	No relaxation	IS 3025 (Part-48): 2025

BDL: Below Detection limit,

DL: Detection limit

Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

Page 2 of 4

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009, India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



Test Report No & Date

:

EETR/E/170326/043, DATE: 23.03.2026

ANALYSIS RESULT

Sr.No.	PARAMETER	UNIT	RESULT	Specification/ Limits As Per IS 10500:2012		TEST METHOD
				Requirement Limit (MAX)	Permissible Limit (MAX)	
20.	Selenium (as Se)	mg/l	BDL(DL-0.05)	0.01	No relaxation	IS 3025 (Part-56): 2003
21.	Aluminium (as Al)	mg/l	BDL(DL-0.05)	0.03	0.2	IS 3025 (Part-55): 2003
22.	Lead (as Pb)	mg/l	BDL(DL-0.05)	0.01	No relaxation	IS 3025 (Part-47): 2024
23.	Total Chromium (as Cr)	mg/l	BDL(DL-0.05)	0.05	No relaxation	IS 3025 (Part- 52): 2003
24.	Boron (as B)	mg/l	BDL(DL-0.3)	0.5	1.0	IS 3025 (Part-57): 2021
25.	Cadmium (as Cd)	mg/l	BDL(DL-0.05)	0.003	No relaxation	IS 3025 (Part-41): 2023

BDL: Below Detection limit,

DL: Detection limit

Reviewed by
PARDEEP



End of the Report***

Page 3 of 4

Evergreen Enviro Testing LLP.

Authorized Signatory
Chandan Kumar Singh

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009, India

Ph.: 0120-4959379, 7428487870. Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



Test Report No & Date

:

EETR/E/170326/043, DATE: 23.03.2026

ANALYSIS RESULT

S. No.	Parameters	Unit	RESULT	Specification/ Limits As Per IS 10500:2012		Test Method
				Requirement Limit	Permissible Limit	
Biological in water						
1.	Escherichia Coli	MPN /100ml	<2	<2 MPN /100ml	No Relaxation	IS:1622:1981
2.	Total Coliform	MPN /100ml	<2	<2 MPN /100ml	No Relaxation	IS:1622:1981

Neelam
Reviewed by
NEELAM SHARMA



Surbhi
Evergreen Enviro Testing LLP
Authorised By
Authorised Signatory
Surbhi Sharma

End of the Report

Page 4 of 4

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.

7


Water Withdrawal Oct 25 to March 26

Month	Bore well -2	Bore well-1	Total
25-Oct	1842.01	368.18	2210.19
25-Nov	1624.55	289.04	1913.59
25-Dec	2858.52	326.50	3185.02
26-Jan	2482.83	389.96	2872.79
26-Feb	2427.37	427.46	2854.83
26-Mar	2866.71	290.82	3157.53

Checked by



STP PHOTO



M/s JK Cement Works (Clinker Grinding Unit)

Village: Satha, Tehsil: Koil, District: Aligarh (U.P)


Annexure- 12

Rain Water Harvesting Pit

plant management has made three rainwater harvesting pits which has capacity of 31,831 m³ per annum.



Rain Water
Harvesting
Pit No-1



Rain Water
Harvesting
Pit No-2



Rain Water
Harvesting
Pit No-3



Annexure 10

J.K.CEMENT WORKS ,ALIGARH ,
Village: Satha, Tehsil: Koil, District: Aligarh (U.P.)

QUARTERLY NOISE LEVEL MONITORING RESULT(April 25 to September 25)

Sr.No.	Month	Day / Night	COMPRESSO	CEMENT	UNLOADING	PACKING	Near DG set
1	Oct/25	Day	67.10	67.20	68.50	68.20	Not Running
2	Nov/25	Day	70.5	70.9	71.1	70.6	Not Running
3	Dec/25	Day	70.9	69.2	69.4	70.1	Not Running
4	Jan/26	Day	69.1	69.4	70.1	69.7	Not Running
5	Feb/26	Day	68.6	68.9	70.8	69.2	Not Running
6	Mar/26	Day	69.1	68.2	69.4	69.8	Not Running

Monitored By



Checked By



6-10-11



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/023
Test Report No & Date	:	EETR/E/170326/023, DATE: 23.03.2026
ULR No.	:	TC166962600000787F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Work zone Noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Inside Compressor Room Area
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Work zone Noise	dB (A)	Max.- 74.1	90	IS:9989-1981
			Min.- 59.8		
			Avg.- 66.95		

Reviewed by
PARDEEP

Evergreen Enviro Testing LLP.

Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1



- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India



Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942
Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/024
Test Report No & Date	:	EETR/E/170326/024, DATE: 23.03.2026
ULR No.	:	TC166962600000788F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Work zone Noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Inside Cement Mill Area
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Work zone Noise	dB (A)	Max.- 69.2	90	IS:9989-1981
			Min.- 57.8		
			Avg.- 63.5		


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorized Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

... 3



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/025
Test Report No & Date	:	EETR/E/170326/025, DATE: 23.03.2026
ULR No.	:	TC166962600000789F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Work zone Noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Inside Packing Plant Area
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Work zone Noise	dB (A)	Max.- 72.6	90	IS:9989-1981
			Min.- 58.8		
			Avg.- 65.7		


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report

Page 1 of 1

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009, India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/026
Test Report No & Date	:	EETR/E/170326/026, DATE: 23.03.2026
ULR No.	:	TC166962600000790F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Work zone Noise
Sample Collected by	:	EET Representative (Mr.Yatesh)
Sampling Location	:	Inside Unloading Area
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	OK
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Work zone Noise	dB (A)	Max.- 72.0	90	IS:9989-1981
			Min.- 58.2		
			Avg.- 65.1		

Reviewed by
PARDEEP



End of the Report

Page 1 of 1

Evergreen Enviro Testing LLP.

Authorised By

Authorised Signatory
Chandan Kumar Singh

Note : 1. The result listed refer only to be Tested samples and applicable parameters.

2. Perishable samples will be destroyed after 15 days of sampling.

3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.

4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com




TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/019
Test Report No. & Date	:	EETR/E/170326/019, DATE: 23.03.2026
ULR No.	:	TC166962600000783F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Site	:	Near Plant Boundary towards north direction
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Environment Condition	:	Clear
Environment Temperature (°C)	:	25.5
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Day	Leq(dB (A))	70.4	75	IS:9989-1981
2.	Night	Leq(dB (A))	59.4	70	IS:9989-1981

Note: Day time - 6:00am to 10:00pm
Night time - 10: 00 pm to 6:00am


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.
Authorised By

Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

... 6



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/020
Test Report No. & Date	:	EETR/E/170326/020, DATE: 23.03.2026
ULR No.	:	TC166962600000784F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Site	:	Near Plant Boundary towards west direction
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Environment Condition	:	Clear
Environment Temperature (°C)	:	29.6
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Day	Leq(dB (A))	69.5	75	IS:9989-1981
2.	Night	Leq(dB (A))	58.8	70	IS:9989-1981

Note: Day time - 6:00am to 10:00pm
Night time - 10: 00 pm to 6:00am


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/021
Test Report No. & Date	:	EETR/E/170326/021, DATE: 23.03.2026
ULR No.	:	TC166962600000785F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient noise
Sample Collected by	:	EET Representative (Mr.Yatesh)
Sampling Site	:	Near Plant Boundary towards east direction
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Environment Condition	:	Clear
Environment Temperature (°C)	:	29.1
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS


S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Day	Leq(dB (A))	70.0	75	IS:9989-1981
2.	Night	Leq(dB (A))	58.4	70	IS:9989-1981

Note: Day time - 6:00am to 10:00pm
Night time - 10: 00 pm to 6:00am


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



TC-16696

EVERGREEN ENVIRO TESTING LLP

Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/022
Test Report No. & Date	:	EETR/E/170326/022, DATE: 23.03.2026
ULR No.	:	TC166962600000786F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Ambient noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Site	:	Near Plant Boundary towards south direction (CCR Office)
Sample Collection Date	:	16.03.2026 To 17.03.2026
Date of Sample Receipt	:	17.03.2026
Environment Condition	:	Clear
Environment Temperature (°C)	:	28.6
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Limit as per CPCB	Test Method
1.	Day	Leq (dB (A))	69.1	75	IS:9989-1981
2.	Night	Leq (dB (A))	57.9	70	IS:9989-1981


Note: Day time - 6:00am to 10:00pm
Night time - 10: 00 pm to 6:00am



Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note :
1. The result listed refer only to be Tested samples and applicable parameters.
 2. Perishable samples will be destroyed after 15 days of sampling.
 3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
 4. Subject to Gr. Noida Jurisdiction.

... 9



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009. India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreenlab.com, Website : www.evergreenlab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/034
Test Report No. & Date	:	EETR/E/170326/034, DATE: 23.03.2026
ULR No.	:	TC166962600000798F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Gen Set Noise
Sample Collected by	:	EET Representative (Mr.Yatesh)
Sampling Location	:	Gen Set No.-1 (1250 KVA)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	Ok
Analysis Duration	:	17.03.2026 To 23.03.2026

ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Requirement as per CPCB	Test Method
1.	Sound Level Door Open	dB (A)	103.1	>25	IS: 4758-1968
2.	Sound Level Door Closed	dB (A)	74.5		
3.	Insertion Loss	dB (A)	28.6		


Reviewed by
PARDEEP



End of the Report

Evergreen Enviro Testing LLP.


Authorized Signatory
Chandan Kumar Singh

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.



EVERGREEN ENVIRO TESTING LLP



Address : 78/2, First Floor, Gaur Plaza (Building No. 2), Lal Kuan, Greater Noida,
G.B. Nagar, Uttar Pradesh - 201009, India

Ph.: 0120-4959379, 7428487870, Mob.: +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

TEST REPORT

ISSUED TO	:	M/S JK CEMENT LTD. ALIGARH- KASIMPUR ROAD, VILLAGE-SATHA, PARGANA-MORTHAL, TEHSIL- KOIL, DISTRICT- ALIGARH (U.P.)
Sample Identification No.	:	EETR/E/170326/035
Test Report No. & Date	:	EETR/E/170326/035, DATE: 23.03.2026
ULR No.	:	TC166962600000799F
Sampling Method	:	EET/SOP/34/CHEM
Sample Description	:	Gen Set Noise
Sample Collected by	:	EET Representative (Mr. Yatesh)
Sampling Location	:	Gen Set No.-2 (125 KVA)
Sample Collection Date	:	16.03.2026
Date of Sample Receipt	:	17.03.2026
Sample Condition	:	Ok
Analysis Duration	:	17.03.2026 To 23.03.2026


ANALYSIS RESULTS

S. No	Test Parameters	Units	Results	Requirement as per CPCB	Test Method
1.	Sound Level Door Open	dB (A)	99.8	>25	IS: 4758-1968
2.	Sound Level Door Closed	dB (A)	73.8		
3.	Insertion Loss	dB (A)	26.0		


Reviewed by
PARDEEP



Evergreen Enviro Testing LLP.


Authorised By
Authorised Signatory
Chandan Kumar Singh

End of the Report
Page 1 of 1

- Note : 1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

Annexure - 14

 JK Cement	Environment Policy	Policy No: FY25/CESD/04 Supersedes: Environment Policy (01) Pages: 1 of 1 Date of Issue: 23/01/2025 Effective Date: 23/01/2025
--	---------------------------	--


Environment Policy

JK Cement Limited (JKCL) promotes environmental protection as a core value in its operations. The company is dedicated to maintain a clean, green, and healthy environment by adhering to responsible practices and continuously improving its efforts in sustainability and resource conservation. JKCL is committed to:

- Ensure full compliance with all relevant laws, regulations, industry standards, and best practices, while adopting any additional measures necessary to go beyond regulatory expectations.
- Make environmental due diligence a core requirement for all upcoming Greenfield and Brownfield projects ensuring the protection of human health and the environment.
- Ensure clearly defined roles and responsibilities for all personnel involved in managing, performing, and verifying activities related to environmental and occupational health & safety (OH&S).
- Optimize resource utilization to enhance environmental management and ensure effective operation of pollution control equipment.
- Implement advanced technologies and robust practices to minimize emissions from our operations, ensuring compliance with regulatory standards & go beyond compliances.
- Set clear, measurable objectives and targets aimed at reducing environmental impacts, such as greenhouse gas (GHG) emissions, air pollutants, and other critical parameters, promoting a culture of continuous improvement.
- Review all active goals and targets at a minimum every 05 years to ensure consistency in our progress. Targets shall be recalculated and revalidated as necessary to align with evolving regulations and requirements.
- Continuously monitor and enhance environmental performance across all units in the areas of air, water, and waste through regular reviews, inspections, and audits.
- Build awareness among all stakeholders on environmental issues and compliance with relevant regulations through training and regular capability building sessions.
- Continuously enhance the effectiveness of our environmental management through a systematic approach for preventing, mitigating, and controlling environmental impacts, across our operations.

The policy shall be reviewed and updated as necessary to align with evolving regulations and best practices. Any amendments will be communicated to all stakeholders in a timely manner.

Approved By:



A.K. SARAOGI
Deputy Managing Director & CFO

EMP Details			
S. No.	Description of Item	Capital Cost (Rs. In Lac)	Recurring cost (Rs. in Lacs)
1	Air Pollution Control Equipment (APC) in the form of Bag filters and Stack	1610.83	14.74
2	Water Pollution Control	242.47	2.0
4	Environmental Monitoring and Management	14.77	0.571
5	Occupational Health	0.25	0
6	Greenbelt / Plantation	7.7	0
7	Others	0	0
Total		1876.02	17.311

Stack Emission Display at Main Gate



X4M6+8XC, Aligarh, Uttar
Pradesh 202127, India
20 May 2026 10:17 am

clear sky
42.0 °C

Your (**Half Yearly Compliance Report**) has been **Submitted** with following details

Proposal No	SIA/UP/IND/24160/2018
Compliance ID	128258688
Compliance Number(For Tracking)	EC/M/COMPLIANCE/128258688/2025
Reporting Year	2025
Reporting Period	01 Dec(01 Apr - 30 Sep)
Submission Date	21-11-2025
RO/SRO Name	Shri Satya Prakash Negi
RO/SRO Email	jhk119@ifs.nic.in
State	UTTAR PRADESH
RO/SRO Office Address	Integrated Regional Offices Lucknow

Note:- SMS and E-Mail has been sent to Shri Satya Prakash Negi, UTTAR PRADESH with Notification to Project Proponent.